

Building Name Address	Use (as per FSA Annexed Table 1)	Date and Time of Incident	Structure and Stories Area	Extent of Damage (Damaged Area/ Total Area)	No. of Casualties
Shiraishi Central Hospital	Hospital  (6) a	Feb. 6, 1977	Fireproof structure, 2 stories above ground and 1 below  Partially wooden, 2 stories above ground	All, Half, <b>Partial</b> , Small  648 m <sup>2</sup>  (33%)	Fatalities 4
		Breakout at 07:41 (approx.) Detected at 07:54 Notified by emergency call  Extinguished by 09:35			
3-N2-3 Heiwa-dori, Shiraishi-ku, Sapporo, HOKKAIDO			Building area 1,238 m <sup>2</sup>		Injured 5 (2)
			Total floor area 1,959 m <sup>2</sup>		

I. Summary of Fire Incident								
(1) Summary	Ninety inpatients (including 6 newborn babies) were in the hospital when this hospital fire occurred. This fire resulted in 4 fatalities (1 seriously ill patient and 3 newborn babies) because of late detection, failure to extinguish the incipient-stage fire, slow communication with the fire station, the action of an irresponsible nurse, lack of duty personnel, and inadequate evacuation procedures.							
	(2) Conditions per Floor	Floor	Total area	Damaged area	Use (Purpose)	No. of persons	No. of fatalities	Fire escape equipment
		m <sup>2</sup>	m <sup>2</sup>					
		Old building, wooden	Old Building		Old Building		Old Building	10 sets of dry-chemical fire extinguishers
		New building, fire resistant	New Building		New Building		New Building	Indoor fire hydrants
PH		18						1 set of outside stairs (1st to 2nd floors)
2		274 429	648	Patients room	38 persons incl 27 patients	73 persons incl 63 patients	4	Automatic fire detection system, Type P Grade 1, 10 lines
(1)		809 429		Exam rooms, Offices Patient rooms, Dining, Kitchen				Guiding lights
Sub Total	1,08 3 876			38 73			2 sets of inside stairs (1st to 2nd floors)	
Total	1,959	648		111	4		Escape chute	
(3) Origin of Fire	(Floor, Room, Part, Combustibles, Habitable/Non-habitable rooms, Present/Absent)					(4) Cause of Fire		
	<p><u>From the wall beneath the window in Exam Room 1 (Hospital Director's office) on the south side of the 1st floor of the old wooden building</u></p> <p>There was an exposed drain pipe and a radiator for the heating system. The pipe passed orthogonally through the wall beneath the window to outside. (The pipe was 405 mm x 28 mm in diameter, and the diameter of the through hole in the wall was 80 mm.) After service personnel defrosted the frozen drain pipe with a burner, he returned to the boiler room. No one was in the room when the fire emerged.</p>						<p>The service personnel defrosted a frozen drain pipe for the steam heating system by leaning the pipe outside the window he opened. Presumably, since he did the same work a day before, the butane burner that he used from the top side of the pipe caused the plaster base inside the wall to become carbonized and caught on fire from smoldering.</p>	

<b>(5) Fire Propagation Path</b>	<div style="display: flex; justify-content: space-around; align-items: center;"> <div style="border: 1px solid black; padding: 5px; width: 15%;">(Location of Fire Source) From the wall beneath the window in Exam Room 1 on the 1st floor of old wooden building</div> <div style="border: 1px solid black; padding: 5px; width: 15%;">(First Spread to) Plaster base of the exterior wall</div> <div style="border: 1px solid black; padding: 5px; width: 15%;">(Propagation from Source) Ceiling, backside of ceiling</div> <div style="border: 1px solid black; padding: 5px; width: 15%;">(Propagation to Adjacent Zones) Hallway</div> <div style="border: 1px solid black; padding: 5px; width: 15%;">(Propagation to Other Floors) Central stairs</div> </div>					
	<p>The fire that emerged from the wall beneath the window in Exam Room 1 burned the plaster base inside the wall and spread to the ceiling, backside of the ceiling, hallway in front of the fire room, and Exam Room 2. From the central stairs near the waiting room, the fire spread quickly to the upstairs because the flame ignited kerosene, which was leaked from the burning hose of a 90-liter service tank containing 70 liters of kerosene for the heating system at that time.</p>					
	<ul style="list-style-type: none"> <li>○ Main Reasons for Propagation of the Fire A flashover that was triggered inside the old wooden building spread the fire instantly and a draft of air on the stairs to the 2nd floor increased the speed of propagation.</li> <li>○ Smoke Propagation Path Hallway to stairs</li> </ul>					
<b>II. Summary of the Building</b>						
<b>(1) Built</b>	Construction, Completion and Major Renovations (Old building) 1964 (New building) 1966					
	<b>(2) Vertical Shafts</b>			<b>(3) Fire Prevention</b>		
<b>Fire Prevention Management</b>	Stairwells <input checked="" type="checkbox"/> Duct spaces <input type="checkbox"/> Elevators <input type="checkbox"/> Pipe shafts <input type="checkbox"/> Escalators <input type="checkbox"/> Other ( ) <input type="checkbox"/>			The hospital had complied with the fire-prevention manager requirement, but after he retired, no-one was appointed as his successor, nor was a report submitted to the fire station after his retirement. The hospital had 2 sets of fire defense plans, one for regular office hours and the other for off-business hours (nighttime and weekend). The hospital carried out a fire drill internally.		
	N/A					
<b>(4) Fire Compartments</b>			<b>(5) Firefighting Equipment</b>			
The 2-story old wooden building was connected with the 2-story new fire-resistive building with a connecting corridor to make two buildings into one large building.			A fire inspection was carried out more than once a year and the inspectors pointed out the need to: <ul style="list-style-type: none"> <li>○ Install a backup battery and priming-water tank for the indoor fire hydrant.</li> <li>○ Fix the transmitter and red lamp of the automatic fire detection system, which were not functioning. (The hospital corrected these issues.)</li> <li>○ Submit an inspection report. (Completed.)</li> </ul>			

III. Actions Taken after the Fire was Detected		
(1) First Detected	<ul style="list-style-type: none"> <li>◦ <b>Detected by</b> ( Night guard and caretaker )</li> <li>◦ <b>How and why</b> ( Alarm sound coming from the automatic fire detection system )</li> <li>◦ <b>Action taken</b> ( Turned of the main alarm and then rushed to the fire location )</li> </ul>	
	<p>Around 07:48, Caretaker A (age 53) who was paying his phone bill for a personal call that he made from the office on the 1st floor of the old building and Hospital Night Guard B (age 63) who was near him heard the alarm sound coming from the automatic fire detection system in the office. The control panel indicated that the fire location was "Outpatient Exam Room 1" and therefore Caretaker A rushed to the fire location. After turning the main alarm off, Guard B followed. When they opened the door to Exam Room 1, smoke had filled the room and the center of the room was burning.</p>	
(2) Emergency Call	<p><b>Emergency Call</b> Yes <input checked="" type="checkbox"/> ( wife of the hospital director )      Time elapsed since detection (    ) minutes          No <input type="checkbox"/> [    ]</p>	
	<p>Kitchen Staff C (age 42) who was preparing breakfast heard the alarm sound inside the kitchen. When she rushed to the fire location, Caretaker A asked her to make a 119 call. She rushed to the office to make the call from the regular land-line telephone, but she was in a panic and could not remember the number, so she alerted Staff D (age 38) who was in the office. Staff D called the hospital director's residence and the wife (age 43) of the director who received the call made a 119 call.</p>	
(3) Initial Firefighting Activities	<p><b>Initiated</b></p> <p>Successful <input type="checkbox"/>    Failed <input checked="" type="checkbox"/></p> <ul style="list-style-type: none"> <li>◦ Extinguished timing <input checked="" type="checkbox"/> [X]</li> <li>◦ Firefighting difficulties <input type="checkbox"/> [ ]</li> <li>◦ Firefighting method <input type="checkbox"/> [ ]</li> </ul>	<p><b>(Reasons or Conditions)</b></p> <p>A little after Caretaker A and Guard B arrived at the burning Exam Room 1, female staff members (caretaker and kitchen helper) brought dry-chemical extinguishers. Caretaker A and Guard B used the extinguishers, directing the contents inside from the door, but their efforts were not successful because the heavy smoke blocked the burning target. They gave up fire control when the fire and smoke became too strong.</p>
	<p><b>Not initiated</b></p> <ul style="list-style-type: none"> <li>◦ Extinguished timing <input type="checkbox"/> [ ]</li> <li>◦ Firefighting difficulties <input type="checkbox"/> [ ]</li> <li>◦ Firefighting method <input type="checkbox"/> [ ]</li> <li>◦ Other <input type="checkbox"/> [ ]</li> </ul>	
(4) Summary of Firefighting Activities	<p><b>(Obstacles or Difficulties in Fire Control)</b></p> <p>By the time firefighters arrived, heavy smoke was pouring out of the clearances around the openings. They could not assess the condition inside because of poor visibility. At that time, they also confirmed intense flames emerging from the south-side windows. As soon as they received information that there were 3 newborn babies in the nursery room on the 2nd floor, each team put on the masks as directed and entered the building from 2 different routes: the main entrance and the north-side escape stairs by knocking down the emergency door. However, they could not enter further because of the intense heat and heavy smoke.</p> <p>Subsequently, another team broke a window on the front side of the 2nd floor and tried to go further inside with a back-up water discharging team, but they had to fall back because of the intense flames. After that, each team encircled the building to prevent the fire from spreading.</p>	

<b>(5) Evacuation</b>	Means of Escape (No. of Persons)	Obstacles to Evacuation
	<ul style="list-style-type: none"> <li>◦ Stairs [ X ] (20)</li> <li>◦ Elevators/Escalators [ ] ( )</li> <li>◦ Escape equipment [ ] ( )</li> <li>◦ Directly to ground from windows or openings [ X ] ( 1 )</li> <li>◦ Rescued [ ] ( )</li> <li>◦ Other ( ) [ ] ( )</li> </ul>	<ul style="list-style-type: none"> <li>◦ No windows [ ]</li> <li>◦ Barred openings [ ]</li> <li>◦ Locked emergency doors (Exits) [ ]</li> <li>◦ Alarm system [ ] (Poorly controlled, Malfunctioned, Not installed)</li> <li>◦ Power outage [ ]</li> <li>◦ Other [ ]</li> </ul>
<p>When the fire alarm alerted staff to the fire, a nurse (age 18) who was on the 2nd floor of the old building told the patients, "It's okay" as if nothing was wrong, and no one even tried to evacuate the building. After a while, one of the nurses noticed smoke coming from the stairs when she was patrolling the building, and then people started to evacuate abruptly. Through the north-side stairs and the kitchen area, 16 out of 21 patients (excluding the babies) in the old building evacuated to the new building. One midwife (age 50) who was in the bathroom on the 2nd floor rushed to the nursery room. She held 3 babies in her arms and escaped with nurse(s) and 4 patients to the outside stairs through the window next to the emergency exit. One caregiver escaped by breaking the wire-meshed window of the emergency exit. The patients in the new building were all evacuated via the emergency exit or elsewhere.</p>		
<b>(6) Casualties</b>	Healthy individuals (Drunk persons ) Individuals in need of assistance 4 Infants 3 Elderly Handicapped Patients/ill persons	Obstacles to Evacuation <ul style="list-style-type: none"> <li>◦ No windows [ ]</li> <li>◦ Barred openings [ ]</li> <li>◦ Locked emergency doors (Exits) [ ]</li> <li>◦ Alarm system [ ] (Poorly controlled, Malfunctioned, Not installed)</li> <li>◦ Power outage [ ]</li> <li>◦ Other [ ]</li> </ul>
	<p>One seriously ill inpatient (age 53) was found face-down beneath the bathroom window on the 2nd floor and died of carbon monoxide poisoning.</p> <p>3 newborn babies died in their beds in the nursery on the 2nd floor.</p>	
<b>IV. Issues and Lessons Learned</b>		
<ol style="list-style-type: none"> <li>1. The fire that emerged from the plaster base inside the wall was not detected until the fire started to burn the surface of the wall. The rate-of-rise heat detector in that room did not detect the rise in temperature since the origin of the fire was furthest away from the detector.</li> <li>2. The 119 call was delayed, so the fire had fully developed by the time firefighters arrived. Because of this, search and rescue activities were impossible when they had received information regarding the people in need of rescue.</li> <li>3. Despite hearing the fire alarm, a nurse carelessly told people that evacuation was unnecessary. This irresponsible action was brought about by a lack of internal communications and lack of preparedness for evacuation procedures in case of an emergency.</li> <li>4. The emergency exit to the outside stairs was always locked by a padlock from inside and the key was stored in the nurse station. When the fire occurred, no-one unlocked this exit.</li> <li>5. The in-house firefighting team was insufficient for nighttime duty and the members lacked knowledge and training. Because of this, they did not respond well as per their responsibilities.</li> <li>6. To solve the fire prevention issues, the hospital was constructing a new building with fireproof features on the premises at that time.</li> </ol>		



